



Representative Image

Catalog No. TQC100S**Description: ENCLOSURE NEMA 1 SURFACE 100A****UPC No 783164020137****Home > Circuit Breakers > Circuit Breaker Enclosures**

GE's circuit breaker enclosures are UL Listed, CSA Certified and are suitable for use as service equipment (except as noted). The short circuit rating of the enclosure/circuit breaker combination is equal to the short circuit rating of the installed circuit breaker. Frame notes and/or restrictions TQD, THQD (2, 3 Pole) ACCESSORIES Neutral Kit (non-GF applications) included 100S Amps 100 A

Descriptors

Category	Circuit Breaker Enclosures
GO Schedule	B2

Specifications

Enclosure Type	NEMA Type 1
Mounting	Surface
Frame Type	Q-Line
Amperage	100 A
Material	Steel
GSA Compliance	No

Classifications

UL/CUL Listing	CSA UL
----------------	-----------

Dimensions

Height	15.2 in
Depth	4.0 in
Width	6.9 in
Weight	7.4 lb