

Test Verification of Conformity

On the basis of the tests undertaken, the sample(s) of the below product have been found to comply with the requirements of the referenced standard and sections at the time the tests were carried out. This verification is part of the full test report(s) and should be read in conjunction with them.


Applicant Name & Address: Panduit Corporation
6200 175th Street
Tinley Park IL 60477
USA

Product Description: Category 6A 4-conductor unshielded channel as illustrated below


Standard(s): ANSI/TIA-568.2-D-2018, *Balanced Twisted-Pair Telecommunications Cabling and Components Standard*, dated September 2018 (Section 6.3: Channel Transmission Performance)

Verification Issuing Office Name & Address: Intertek Testing Services NA, Inc.
3933 US Route 11,
Cortland, NY 13045

Test Report Number(s): 104448628CRT-001a



Component Id	Manufacturer	Description	Part number
1	Panduit	Equipment Cord	UTP6AX5M**
2	Panduit	Module	CJ6X88TG**
3	Panduit	Horizontal Cable	PUO6AS04**
4	Panduit	Transition Point	FP6X88MTG
5	Panduit	Cross Connect	UTP6AX2M**
6	Panduit	Equipment Cord	UTP6AX3M**



Signature

Name: Antoine Pelletier
Position: Project Engineer
Date: 25-September-2020

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.